



**NOTES:**

1. ALL WALLS TO BE 150mm THICK.
2. WHERE PIPE DIA. EXCEEDS PIT WIDTH OR DEPTH EXCEEDS 2.0m REFER TO STD. DRAWING No. S255.
3. WEEPHOLE, 100mm DIA. IN THE WALL UNDER THE KERB & CHANNEL TO BE 100mm BELOW SUBGRADE LEVEL.
4. SHAPE PIT INVERT TO ONE THIRD OUTLET PIPE DIAMETER.
5. CONCRETE INFILL SUPPORT FOR KERB AND CHANNEL TO BE PROVIDED BETWEEN CONSTRUCTION JOINTS TO A DEPTH OF 100mm AT THE FACE OF THE PIT.
6. CONCRETE STRENGTH 25MP<sub>a</sub> AT 28 DAYS.
7. PROVIDE STEP IRONS FOR PIT DEPTH EXCEEDING 1.0m, REFER TO STD. DRAWING No. S275.

ALL DIMENSIONS IN mm.

	<b>SIDE ENTRY PIT(900x600) WITH A CAST IRON COVER FOR B2 KERB &amp; CHANNEL</b>		APPROVED  MANAGER ENGINEERING SERVICES DRAWING No.
	DRAWN: V. NGUYEN	CHECKED: S.Q	AMENDMENTS: APRIL 2011
	SCALE: 1:20	DATE: MAY 2011	BY: MURRAY BASILE
			S250